CIVIL TECH LABS

Accredited by NABL as per ISO/ IEC 17025 : 2005

5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027

Ph: 080 - 4114 2867 / Mob. : 96862 31801, Email: civiltechlabs@gmail.com

T-2654

To,

Assistant Executive Engineer
Vidyaranyapura Sub Division,
BBMP, Bangalore.

31st May 2014

Dear Sir,

Sub: Providing Street signage board in ward no. 10 area (Doddabommasandra) Vidyaranyapura.
Testing of cubes – Reg.

As requested the 28th day Compressive Strength Test of Cubes was carried out for the above work for the samples supplied by you.

Please find the enclosed Test Report of the above.

Thanking you,

For Civil Tech Labs,

CIVIL TECH LABS BANGALORE

(KHUSHBOO L.)
Deputy Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ. ಪಾ., ಬೆಂಗಳೂರು-97

CIVIL TECH LABS

TEST REPORT ON CONCRETE CUBES

Name of the Client	AEE, Vidyaranyapura Sub Division, BBMP
Project	Providing Street signage board in ward no. 10 area (Doddabommasandra) Vidyaranyapura.
Agency	Sri. R. Madhusudan
Grade of Concrete	M-15
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 Sq.mm
Technical Reference	IS: 516-1959(Reaffirmed 2004)

Sl.No	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/Sq.mm)	Avg Compressive Strength (N/Sq.mm)
1	CC-Work (Column)	03/05/2014	31/05/2014	28	8.15	350	15.56	15.61
2					8.16	356	15.82	
3					8.14	348	15.47	

Note:

1 The results relate only to the items tested.
2 Report shall not be reproduced except in full, without the written approval of the lab.
3 Any correction invalidates this report.
4 The results are based on the test conducted on samples supplied by the client.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
5, I Floor I Cross
Srinivasa Colony, [illegible] Road
BANGALORE - [illegible]

Jadhav
AE ward

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ.
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ.
ಯಲಹಂಕ ವಲಯ,
ಬ. ಬೆಂ. ಮ ಪಾ. ಬೆಂಗಳೂರು-97

CIVIL TECH LABS

Accredited by NABL as per ISO/ IEC 17025 : 2005

5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027

Ph: 080 - 4114 2867 / Mob. : 96862 31801, Email: civiltechlabs@gmail.com

T-2654

To,

Assistant Executive Engineer
Vidyaranyapura Sub Division,
BBMP, Bangalore.

10th June 2014

Dear Sir,

Sub: Providing Street signage board in ward no. 10 area (Doddabommasandra) Vidyaranyapura.
Testing of cubes – Reg.

As requested the 28th day Compressive Strength Test of Cubes was carried out for the above work for the samples supplied by you.

Please find the enclosed Test Report of the above.

Thanking you,

For Civil Tech Labs,

CIVIL TECH LABS BANGALORE

(KHUSHBOO L.)
Deputy Quality Manager

Jadhav
AE W-10

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ ಸಾ. ಬೆಂಗಳೂರು-97.

CIVIL TECH LABS

TEST REPORT ON CONCRETE CUBES

Name of the Client	AEE, Vidyaranyapura Sub Division, BBMP
Project	Providing Street signage board in ward no. 10 area (Doddabommasandra) Vidyaranyapura.
Agency	Sri. R. Madhusudan
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 Sq.mm
Technical Reference	IS: 516-1959(Reaffirmed 2004)

Sl.No	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/Sq.mm)	Avg Compressive Strength (N/Sq.mm)
1	CC-Work (Pavement)	13/05/2014	10/06/2014	28	8.17	465	20.67	21.04
2					8.18	475	21.11	
3					8.20	480	21.33	

Note:

1 The results relate only to the items tested.
2 Report shall not be reproduced except in full, without the written approval of the lab.
3 Any correction invalidates this report.
4 The results are based on the test conducted on samples supplied by the client.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
5, I Floor I Cross
Srinivasa Colony, Misssion Road
BANGALORE - 560 027

Jadhav
AE W-10

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ. ಸಾ., ಬೆಂಗಳೂರು-9.